

Planning Division  
15151 E. Alameda Parkway, Ste. 2300  
Aurora, Colorado 80012  
303.739.7250



May 22, 2019

Alex Salmins  
The Architerra Group  
5881 S. Deframe Street  
Littleton, Co 80127

**Re: High Plains Country Club**  
Case Number: 2003-4013-58

Dear Mr. Salmins:

Thank you for your submission for the above named minor amendment. We reviewed it and have the following comment:

- A. Civil Engineering** Kristen Tanabe Project Engineer 303-739-7306 [ktanabe@auroragov.org](mailto:ktanabe@auroragov.org)
1. The site plan will not be approved by Public Works until the preliminary drainage letter/report is approved.
- B. Forestry** Rebecca Lamphear Environmental Inspector 303-739-7177 [rlamphea@auroragov.org](mailto:rlamphea@auroragov.org)
1. Evergreens are measured by height. Please update size of evergreens used as mitigation inches.  
For example  
6' evergreen=3" of mitigation  
8' evergreen=4" of mitigation  
10' evergreen=5" of mitigation

Please resubmit your work with the requested changes. Contact each person making the comments and cc me with any emails. You may email it directly to me at [wbarrett@auroragov.org](mailto:wbarrett@auroragov.org) . Should you have any questions you may contact me via email or by calling 303.739.7133

Sincerely,

W. David Barrett  
Sr. Planner II