

September 4, 2024
703 N Salida Way
MFH Environmental/Vine Laboratories
Case Number: 2022-6002-02

3rd Submittal Comment Response

3. Fire / Life Safety (Mark Apodaca / 303-739-7656 / mapodaca@auroragov.org / Comments in blue)
3A. Replace "Access" with Lane. [Note 3A- Shown on "A2.1 Site A2.1 NEW BUILDING"](#)
3B. Show the existing fire lane easement delineation at the entrance of the site. [Note 3B- Shown on "A2.1 Site A2.1 NEW BUILDING"](#)
3C. Show the Knox box and label. [Note 3C - Shown on "A9.1 elevations"](#)
4. Aurora Water (Steven Dekoski / 303-739-7490 / sdekoski@auroragov.org / Comments in red)
4A. Why is a second water meter proposed for this lot? Water fixture unit tables required with civil plans to determine the water meter size.
[4A. Noted on sheet 4 of "Civil Comment Response rev 1" - The water comment is not applicable because we don't propose the second meter any longer. The comment is written on the utility plan from the initial submittal and was revised for the resubmittal](#)
4B. Please contact Steve DeKoskie for questions regarding Water's comments in RED. sdekoski@auroragov.org