



Right of Way & Permits

1123 West 3rd Avenue
Denver, Colorado 80223
Telephone: **303.571.3306**
Facsimile: 303.571.3284
donna.l.george@xcelenergy.com

October 10, 2024

City of Aurora Planning and Development Services
15151 E. Alameda Parkway, 2nd Floor
Aurora, CO 80012

Attn: Maria Alvarez

Re: Lussing Trust North Lateral, Case # DA-2201-10

Public Service Company of Colorado's (PSCo) Right of Way & Permits Referral Desk has reviewed the site plan for **Lussing Trust North Lateral**. Please be aware PSCo owns and operates existing both overhead and underground electric distribution facilities along Monaghan Road. Bear in mind that per OSHA standards, a minimum 10-foot radial clearance must be maintained at all times from all overhead electric facilities including, but not limited to, construction activities and permanent structures.

Note that proper clearances must be maintained including ground cover over buried facilities that should not be modified from original depths. In other words, if the original cover is changed (by less or more), PSCo facilities must be raised or lowered to accommodate that change. Contact Colorado 811 for locates before excavating. Use caution and hand dig when excavating within 18-inches of each side of the marked facilities. Please be aware that all risk and responsibility for this request are unilaterally that of the Applicant/Requestor.

Donna George
Right of Way and Permits
Public Service Company of Colorado dba Xcel Energy
Office: 303-571-3306 – Email: donna.l.george@xcelenergy.com