



OWL Services
6235 Southern Blvd
Youngstown, OH 44512

March 11, 2024

City of Aurora
Planning Division
15151 E. Alameda Parkway, Ste. 2300
Aurora, Colorado 80012

To Whom It May Concern

In response to the corrections letter issued by your office on February 29, 2024 for the electric vehicle charger project at the Circle K located at 298 S Potomac St, we offer the following responses. Plans have also been adjusted slightly based upon newly received survey info. Revised drawings have been included with this resubmission.

1. Landscaping

- 1) Different Symbolology has been used as requested. A symbols legend has been included on the sheet
- 2) Bed Treatment and edge has been identified. The beds shall be comprised of stone to match those of the existing beds on site.
- 3) Required calipers and plant sizing has been noted in the planting schedule as outline in the corrections letter issued by your office. Bed treatment for the new trees has also been identified. It shall be stone to match the existing planting beds on site.
- 4) The proposed ash tree has been changed to be a shademaster honeylocust.
- 5) Shrub sizes of 5 gallon minimum have been listed in the planting schedule.
- 6) Trees have been added to the planting schedule along with the caliper or height conforming with the city's standards

We hope these responses assist with your approval of this project.


Phillip J Jaminet
Director of Engineering