

December 24, 2018

City of Aurora  
15151 E Alameda Parkway,  
Aurora, CO 80012

The responses below correspond directly to Zoning Review comments made for by **W. David Barrett, Rebecca Lamphear & Greg Rogers:**

Electrify America installation Electric Vehicle Charging Stations at Walmart (1492) 14000 E. Exposition Ave., Aurora, CO 80012; Aurora Walmart Case Number 1989-6022-15

---

1. Add some shrubs around the conduit stubs.

**BV Response: Conduit stubs will be cut and capped below grade. Shrubbery will not be necessary to hide conduits as they will be below grade.**

2. Add the relevant codes to T-1

**BV Response: Codes updated on Title Sheet T-1 to reflect the following:**

- 2015 International Building Code (IBC)
- 2015 International Residential Code (IRC)
- 2015 International Mechanical Code (IMC)
- 2015 International Fuel Gas Code (IFGC)
- 2015 International Fire Code (IFC)
- 2015 International Plumbing Code (IPC)
- 2015 International Existing Building Code (IEBC)
- 2015 International Energy Conservation Code (IECC)
- 2017 National Electrical Code (NEC)

3. Any Trees that are preserved in the site during construction activities shall follow the standard details for tree Protection per the current Parks, Recreation & Open Space Dedication and Development Criteria manual. Parks, Recreation & Open Space Dedication and Development Criteria manual. These notes shall be added to the plan. Tree protection should be installed prior to commencement of work.

**BV Response: Fence protection detail added to landscape sheet LS-1. Protective fence notes added to plans, refer to General Notes sheet GN-3.**

Please contact Skyler Martin in our Kansas City office if you have any questions or comments.

Sincerely,

Skyler Martin, P.E, Design Engineer  
**913-458-2878**  
[MartinS@BV.com](mailto:MartinS@BV.com)