

March 7, 2025

**Travis Reynolds
City of Aurora Planning Department**

**RE: Resubmittal Review - Downtown Aurora Visual Arts - Site Plan Amendment
 Case Number - 2014-6038-01**

Hello Travis,

Please find the submitted comments each numbered below, as well as the amended Site Plan on a separate attachment.

Thank you,

Russ Williams

RE: Resubmittal Review - Downtown Aurora Visual Arts - Site Plan Amendment
Case Number - 2014-6038-01

PLANNING DEPARTMENT COMMENTS

1. Planning (Jamie Hartig / 720-692-6775 / treynold@auroragov.org / Comments in teal)

- Approved 12/13/24 – No Comments
- **Thank you no changes were made**

1. Traffic Engineering (Steven Gomez / +1 (303) 501-3217/ segomez@auroragov.org/ Comment in Orange

2A.

- Approved. 8/1/24 - No Comments.
- **Thank you no changes were made**

2. Land Development (Su Wever / swever@auroragov.org/ PDF Comments in Magenta

3A.

- Approved. 8/1/24 - No Comments.
- **Thank you, no changes were made**

3. Fire Life Safety (Safety (Steve Kirchner/ 303-739-7489 / stkirchn@auroragov.org) See [blue comments](#)

4A. DA 2.0

- Repeat request. Provide a description of the gate stating gate width, type of gate (sliding, cantilever, etc.), whether it is manual or automatic, and with Approved Knox Hardware. See examples provided.
- **Thank you, the gate description was added (23' Manual swing gate with approved Knox Hardware) to page DA 2.0**

4B. Sheet 16

- This appears to be the location of the lock. Please show the Knox box at either of the identified locations and move the Knox box symbol.
- **Thank you, the knox box location was corrected and added to page 16 DA 12.0**