

Master Utility Report

The Southwest Corner of Stephen D. Hogan Parkway and Picadilly Road

Eagle Ridge

A Portion of the Northeast Quarter of Section 11, Township 4 South,
Range 66 West of the Sixth Principal Meridian, City of Aurora, County of
Arapahoe, State of Colorado

Prepared for: Kevin Beck
EVC-WDG Aurora One, LLC
3501 SW Fairlawn Road, Suite
200
Topeka, KS 66614

Prepared for: Ryan Zent
Overland Land Group, LLC
1732 Wazee Street, Suite 202
Denver, CO 80202

Prepared by: Nicholas Andersen
Reviewed by: Michael Beach, P.E.
Ridgetop Engineering and
Surveying
541 E. Garden Drive, Unit N
Windsor, CO 80550

Date: May 27, 2024

Approved For One Year From This Date	
<hr/>	
<hr/>	<hr/>
Fire Department	Date
<hr/>	<hr/>
Water Department	Date



541 E Garden Drive, Unit N Windsor, CO 80550
(970) 663-4552 EMAIL: nandersen@ridgetopeng.com/mbeach@ridgetopeng.com

CERTIFICATION

I hereby certify that this Master Utility Report for Eagle Ridge was prepared by me (or under my direct supervision) in accordance with the provisions of the City of Aurora Standard Specifications regarding Water and Sanitary Infrastructure.

Mike Beach
State of Colorado Registration No. 45088
Ridgetop Engineering

Date

Table of Contents

General Location and Description	4
Site Location	4
Description of Development	4
Water	5
Existing Infrastructure	5
Proposed Development	5
Anticipated Demand and Design Criteria	5
Sanitary Sewer	6
Existing Infrastructure	6
Proposed Infrastructure	6
Design Standards	6
Conclusion	6
References	6

Appendices

Appendix A

 Concept Water Design Plan

 Concept Sewer Design Plan

Appendix B

 Concept Water Modeling Layout

 Preliminary Water Demand Calculations

Appendix C

 Preliminary Sewer Demand Calculations

Appendix D

 Land Use Plan

Appendix E

 Excerpts


Project Narrative

I. GENERAL LOCATION AND DESCRIPTION

A. Site Location

The Eagle Ridge property is a 39.27 acre parcel bound by Stephen D. Hogan Parkway to the north, Picadilly Road to the east, and Coal Creek/vacant land to the south and west.

Northeast Quarter Section 11, Township 4 South, Range 66 West of the 6th P.M., City of Aurora, County of Arapahoe, State of Colorado.



VICINITY MAP

1" = 2000'

B. Description of Development

Eagle Ridge is planned to be a mixed use development consisting of commercial and multi-family residential uses. The development is divided into six planning areas that will be accessed by proposed internal private roadways. Water and sanitary sewer mains will be extended through the property via the internal private roads to provide service to each of the planning areas. Storm sewer infrastructure mains will be provided at each lot and will convey stormwater runoff to two proposed on-site detention areas. Planning area one will consist of all commercial development and planning area two will be multi-family. Planning areas three, four, and five are proposed to be all commercial use. Planning area six is dedicated to meet the open space

requirements and therefore no water or sewer improvements are planned for PA-6. Refer to the appendix for the Land Use Plan.

II. WATER

A. Existing Infrastructure

A 16" domestic water main is currently proposed to be constructed along the east side of the property located within Picadilly Road adjacent to the site. Water is also available northwest of the property within Stephen D. Hogan Parkway (SDH) approximately 700 feet to the northwest and will be extended east to the property. The property lies within the City of Aurora pressure Zone 3, which indicates a static pressure range from 77 psi to 92 psi. The water main in Picadilly Road is proposed to be a 16" main and has a static pressure of 90 psi. The existing water main in SDH provides an 8" stub to the south side of SDH and has a static pressure of 82.6 psi.

An existing water well is currently serving the existing home located on the eastern edge of the property. This home will be demolished with the development and the well will be abandoned.

B. Proposed Development

The Eagle Ridge development is proposing to extend 8" water mains from Picadilly Road to SDH Parkway to create a looped water main. This will be achieved by constructing the 8" main through the internal private road from the existing 16" main in Picadilly to the existing 8" stub in SDH. Within the site, planning area one will connect each commercial lot directly to the 8" water main proposed within the private road. Planning areas two and three will have multiple future internal mains extended through their respective boundaries to provide services to the phased developments. See appendix for a map of the proposed and existing water infrastructure.

C. Anticipated Demand and Design Criteria

The *Water, Sanitary Sewer and Storm Drainage Infrastructure Manual*, City of Aurora, CO, effective January 2022 Section 5.02 was referenced for all design criteria. Using Section 5.02.3 Domestic Water Demand per Zoning Classification, the proposed water demands have been calculated and a breakdown of the demands is shown in the appendix. The modeled scenarios include average day demand, maximum hourly demand, and maximum day plus fire flow.

Fire flow demands for the Multi-family residential areas were calculated at 2,500 gpm, as well as the Commercial areas, see table below for demand classifications. For purposes of this report, the combined fire flows for Planning area 4 has been modeled for the fire flow plus Max Day Demand analysis. Residual pressures and velocities conform to the requirements of Section 5.02 of the City of Aurora Standards and Specifications, with the minimum pressure achieved of 87.18 psi.

Use Classification	Fire Flow Demand
Residential	1,500 gpm for 2 hrs
Commercial/Multifamily	2,500 gpm for 2 hrs
Industrial	3,500 gpm for 2 hrs

III. SANITARY SEWER

A. Existing Infrastructure

Sanitary Sewer infrastructure is currently existing within the Picadilly Road right of way and along the southern property boundary within a 30' wide Utility Easement. The Picadilly Road sanitary sewer is an existing 18" pvc main with an approximate depth of 28' from rim to invert. At the south property boundary, the existing sewer main is a 42" PVC with varying depths of 15' to 20' rim to invert. The existing sanitary sewer infrastructure has sufficient depth and capacity for the proposed development.

B. Proposed Infrastructure

It is proposed to extend an 8" PVC sanitary sewer main through the private road that will connect to the existing 42" along the southern property boundary. This new sewer main will provide sanitary services to all planning areas of the development, with the exception of Planning area 6 (open space). Calculations for peak hour flow of each planning area are provided in the appendix.

C. Design Standards

The *Water, Sanitary Sewer and Storm Drainage Infrastructure Manual*, City of Aurora, CO, Effective January 2022 Section 5.03 was referenced for all design criteria. Offsite flows from the approved Horizon Uptown City Center Master Utilities Report, as well as the Aurora One Master Utility Report were added to the downstream flows in order to accurately analyze the existing sewer infrastructure. Sanitary Average and Peak demands, design slopes, pipe sizes, and pipe capacities have been provided with the appendix.

IV. CONCLUSION


A. Conclusion

As described above, there is adequate existing water and sewer infrastructure to provide water and sewer service to the proposed development. The existing 16" water mains, as well as the existing 42" sewer main provide the necessary capacity for the required demands.

V. REFERENCES

- *Water, Sanitary Sewer and Storm Drainage Infrastructure Manual*, City of Aurora, CO, effective January 2022.
- *Aurora One Master Utility Report* – Ware Malcomb dated 2/18/2021

Appendix A




LEGEND

EX. CONTOUR	- - - - -24-
PROPERTY LINE	— — — — —
EAGLE BUFFER	— — — — —
PLANNING AREA	- - - - -
CONCEPTUAL 8/12" WATER MAIN	— — — — —
CONCEPTUAL 8" WATER MAIN SPECIFIC TO PLANNING AREA	- - - - -
WATER SERVICE	— — — — —

APPROVED FOR ONE YEAR FROM THIS DATE


FIRE DEPARTMENT _____ DATE _____

AURORA WATER – UTILITIES DIVISION _____ DATE _____



File: A:\HOMSP - Util Report WE1 Planning Areas.dwg Path: P:\Colorado\Aurora\Equity Ventures\22-064-023 Hogan & Picadilly Aurora One Master Plan\2 Drawings\ Plotted by: Ryan Date: 27-May-24 11:37:51am

File: A:\HOMSP - Util Report SE1 Sewer Map.dwg Path: P:\Colorado\Aurora\Equity Ventures\#22-064-023-Hogan & Picadilly Aurora One Master Plan\Drawings\ Plotted by: Ryan Date: 27-May-24 11:36:57am




LEGEND

- EX. CONTOUR
- PROPERTY LINE
- EAGLE BUFFER
- PLANNING AREA LIMITS
- SANITARY MAIN
- DESIGN POINT


APPROVED FOR ONE YEAR FROM THIS DATE

 DATE

AURORA WATER - UTILITIES DIVISION




Appendix B



LEGEND

- EX. CONTOUR
- PROPERTY LINE
- EAGLE BUFFER
- CONCEPTUAL WATER MAIN
- CONCEPTUAL WATER MAIN SPECIFIC TO PLANNING AREA
- WATER SERVICE
- JUNCTION
- PIPE/LINK



File: A:\HOMSP - Util Report WE2 Water Mod.dwg Path: P:\Colorado\Aurora\Equity Ventures\22-064-023-Hogan & Picadilly Aurora One Master Plan\2 Drawings\ Plotted by: Ryan Date: 27-May-24 11:36:35am

Average Day Demand (gpm) Eagle Ridge

Planning Area	Junction Node																			
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
PA-1	1.1	1.3	1.1	0.6	0.8		2.6													
PA-2																			19.0	19.0
PA-3								0.8	0.8	1.4	1.0									
PA-4																			4.8	
PA-5												1.0			3.1	3.1	2.1	1.0		
PA-6																	7.0			
Total	1.1	1.3	1.1	0.6	0.8	0.0	2.6	0.8	0.8	1.4	1.0	1.0	0.0	0.0	3.1	3.1	9.1	1.0	23.8	19.0

Maximum Day Demand (gpm) Eagle Ridge

Planning Area	Junction Node																			
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
PA-1	3.2	3.8	3.1	1.7	2.4		7.3													
PA-2																			53.2	53.2
PA-3								2.3	2.3	3.9	2.8									
PA-4																			13.3	
PA-5												2.9			8.8	8.8	5.9	2.9		
PA-6																	19.6			
Total	3.2	3.8	3.1	1.7	2.4	0.0	7.3	2.3	2.3	3.9	2.8	2.9	0.0	0.0	8.8	8.8	25.4	2.9	66.6	53.2

Maximum Hourly Demand (gpm) Eagle Ridge

Planning Area	Junction Node																			
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21
PA-1	5.1	6.0	4.9	2.7	3.8		11.8													
PA-2																			85.6	85.6
PA-3								3.6	3.6	6.3	4.5									
PA-4																			21.4	
PA-5												4.7			14.2	14.2	9.4	4.7		
PA-6																	31.4			
Total	5.1	6.0	4.9	2.7	3.8	0	11.8	3.6	3.6	6.3	4.5	4.7	0	0	14.2	14.2	40.9	4.7	107.0	85.6

Fire Flow + MDD (gpm)
Eagle Ridge

Planning Area	Junction Node																				Fire	Total	
	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21			
PA-1	3.2	3.8	2503.1	1.7	2.4		7.3															2500	2521
PA-2																			1053.2	1553.2		2500	2606
PA-3								2.3	2.3	2503.9	2.8											2500	2511
PA-4										1500.0										1013.3		2500	2513
PA-5												2.9			1508.8	1008.8	5.9	2.9				2500	2529
PA-6																	19.6					-	20
Total MDD	3.2	3.8	3.1	1.7	2.4	0	7.3	2.3	2.3	3.9	2.8	2.9	0	0	8.8	8.8	25.4	2.9	66.6	53.2			

* Fire Flow + MDD has been analyzed by flowing the overall Max Daily Demand plus Planning area 4 fire flows for a total demand of 2,701.4 gpm.

Average Day Demand

Network Table - Nodes

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 2	5512	1.1	1.10	5722.65	91.27
Junc 3	5509.75	1.3	1.30	5722.64	92.25
Junc 4	5508	1.1	1.10	5722.64	93.00
Junc 5	5505	0.6	0.60	5722.64	94.30
Junc 6	5501	0.8	0.80	5722.64	96.04
Junc 7	5500	0	0.00	5722.64	96.47
Junc 8	5500	2.6	2.60	5722.64	96.47
Junc 9	5498.75	0.8	0.80	5722.64	97.01
Junc 10	5495.5	0.8	0.80	5722.64	98.42
Junc 11	5492.25	1.4	1.40	5722.64	99.83
Junc 12	5494.25	1.0	1.00	5722.64	98.96
Junc 13	5494.5	1.0	1.00	5722.64	98.85
Junc 14	5512	0	0.00	5722.64	91.27
Junc 16	5494	3.1	3.10	5722.64	99.07
Junc 17	5494.5	3.1	3.10	5722.64	98.85
Junc 18	5492	9.1	9.10	5722.64	99.94
Junc 19	5495	1.0	1.00	5722.64	98.64

Average Day Demand

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 20	5499.25	23.8	23.80	5722.64	96.79
Junc 21	5504.5	19	19.00	5722.64	94.52
Junc SDH	5504	0	0.00	5722.65	94.74
Resvr PIC	5722.65	#N/A	-71.60	5722.65	0.00

Average Day Demand

Network Table - Links

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 3	227.75	12	150	71.60	0.20
Pipe 4	235.78	8	150	22.91	0.15
Pipe 5	109.80	8	150	21.61	0.14
Pipe 6	85.63	8	150	20.51	0.13
Pipe 7	93.83	8	150	19.91	0.13
Pipe 8	77.84	8	150	19.11	0.12
Pipe 9	92.60	8	150	6.16	0.04
Pipe 10	130.70	8	150	3.56	0.02
Pipe 11	123.32	8	150	2.76	0.02
Pipe 12	182.32	8	150	1.96	0.01
Pipe 13	151.59	8	150	0.56	0.00
Pipe 14	79.48	8	150	-0.44	0.00
Pipe 15	729.72	8	150	16.54	0.11
Pipe 17	254.43	8	150	15.10	0.10
Pipe 18	157.73	8	150	5.67	0.04
Pipe 19	621.12	8	150	6.33	0.04
Pipe 20	154.88	8	150	3.23	0.02

Average Day Demand

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 21	619.47	8	150	-5.87	0.04
Pipe 22	760.01	8	150	-1.20	0.01
Pipe 24	506.4	8	150	12.04	0.08
Pipe 25	411.34	8	150	-12.95	0.08
Pipe 23	297.04	8	150	31.04	0.20
Pipe 16	273.68	8	150	16.54	0.11
Valve 2	#N/A	8	#N/A	16.54	0.11

Max Day Demand

Network Table - Nodes

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 2	5512	3.2	3.20	5722.63	91.26
Junc 3	5509.75	3.8	3.80	5722.61	92.23
Junc 4	5508	3.1	3.10	5722.60	92.99
Junc 5	5505	1.7	1.70	5722.59	94.28
Junc 6	5501	2.4	2.40	5722.59	96.01
Junc 7	5500	0	0.00	5722.58	96.44
Junc 8	5500	7.3	7.30	5722.58	96.44
Junc 9	5498.75	2.3	2.30	5722.58	96.99
Junc 10	5495.5	2.3	2.30	5722.58	98.39
Junc 11	5492.25	3.9	3.90	5722.58	99.80
Junc 12	5494.25	2.8	2.80	5722.58	98.93
Junc 13	5494.5	2.9	2.90	5722.58	98.83
Junc 14	5512	0	0.00	5722.59	91.25
Junc 16	5494	8.8	8.80	5722.57	99.04
Junc 17	5494.5	8.8	8.80	5722.56	98.82
Junc 18	5492	25.4	25.40	5722.56	99.90
Junc 19	5495	2.9	2.90	5722.57	98.61

Max Day Demand

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 20	5499.25	66.6	66.60	5722.57	96.76
Junc 21	5504.5	53.2	53.20	5722.58	94.49
Junc SDH	5504	0	0.00	5722.63	94.73
Resvr PIC	5722.65	#N/A	-201.40	5722.65	0.00

Max Day Demand

Network Table - Links

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 3	227.41	12	150	201.40	0.57
Pipe 4	235.78	8	150	64.55	0.41
Pipe 5	109.80	8	150	60.75	0.39
Pipe 6	85.63	8	150	57.65	0.37
Pipe 7	93.83	8	150	55.95	0.36
Pipe 8	77.84	8	150	53.55	0.34
Pipe 9	92.60	8	150	17.32	0.11
Pipe 10	130.70	8	150	10.02	0.06
Pipe 11	123.32	8	150	7.72	0.05
Pipe 12	182.32	8	150	5.42	0.03
Pipe 13	151.59	8	150	1.52	0.01
Pipe 14	79.48	8	150	-1.28	0.01
Pipe 15	729.72	8	150	46.52	0.30
Pipe 16	273.68	8	150	46.52	0.30
Pipe 17	254.43	8	150	42.34	0.27
Pipe 18	157.73	8	150	15.78	0.10
Pipe 19	621.12	8	150	17.75	0.11

Max Day Demand

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 20	154.88	8	150	8.95	0.06
Pipe 21	619.47	8	150	-16.45	0.10
Pipe 22	760.01	8	150	-3.56	0.02
Pipe 23	297.04	8	150	87.13	0.56
Pipe 24	506.4	8	150	33.93	0.22
Pipe 25	411.34	8	150	-36.23	0.23
Valve 1	#N/A	8	#N/A	46.52	0.30

Max Hour Demand

Network Table - Nodes

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 2	5512	5.1	5.10	5722.60	91.25
Junc 3	5509.75	6.0	6.00	5722.55	92.20
Junc 4	5508	4.9	4.90	5722.52	92.95
Junc 5	5505	2.7	2.70	5722.51	94.25
Junc 6	5501	3.8	3.80	5722.50	95.97
Junc 7	5500	0	0.00	5722.48	96.40
Junc 8	5500	11.8	11.80	5722.48	96.40
Junc 9	5498.75	3.6	3.60	5722.48	96.94
Junc 10	5495.5	3.6	3.60	5722.48	98.35
Junc 11	5492.25	6.3	6.30	5722.48	99.76
Junc 12	5494.25	4.5	4.50	5722.48	98.89
Junc 13	5494.5	4.7	4.70	5722.48	98.78
Junc 14	5512	0	0.00	5722.51	91.21
Junc 16	5494	14.2	14.20	5722.46	98.99
Junc 17	5494.5	14.2	14.20	5722.44	98.77
Junc 18	5492	40.9	40.90	5722.44	99.85
Junc 19	5495	4.7	4.70	5722.45	98.56

Max Hour Demand

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 20	5499.25	107.0	107.00	5722.45	96.71
Junc 21	5504.5	85.6	85.60	5722.49	94.45
Junc SDH	5504	0	0.00	5722.60	94.72
Resvr PIC	5722.65	#N/A	-323.59	5722.65	0.00

Max Hour Demand

Network Table - Links

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 3	227.41	12	150	323.59	0.92
Pipe 4	235.78	8	150	103.62	0.66
Pipe 5	109.80	8	150	97.62	0.62
Pipe 6	85.63	8	150	92.72	0.59
Pipe 7	93.83	8	150	90.02	0.57
Pipe 8	77.84	8	150	86.22	0.55
Pipe 9	92.60	8	150	27.89	0.18
Pipe 10	130.70	8	150	16.09	0.10
Pipe 11	123.32	8	150	12.49	0.08
Pipe 12	182.32	8	150	8.89	0.06
Pipe 13	151.59	8	150	2.59	0.02
Pipe 14	79.48	8	150	-1.91	0.01
Pipe 15	729.72	8	150	74.77	0.48
Pipe 16	273.68	8	150	74.77	0.48
Pipe 17	254.43	8	150	68.17	0.44
Pipe 18	157.73	8	150	25.37	0.16
Pipe 19	621.12	8	150	28.60	0.18

Max Hour Demand

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 20	154.88	8	150	14.40	0.09
Pipe 21	619.47	8	150	-26.50	0.17
Pipe 22	760.01	8	150	-5.83	0.04
Pipe 23	297.04	8	150	140.11	0.89
Pipe 24	506.4	8	150	54.51	0.35
Pipe 25	411.34	8	150	-58.33	0.37
Valve 1	#N/A	8	#N/A	74.77	0.48

Fire Flow + MDD

Network Table - Nodes

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 2	5512	3.2	3.20	5719.86	90.07
Junc 3	5509.75	3.8	3.80	5716.62	89.64
Junc 4	5508	3.1	3.10	5715.12	89.75
Junc 5	5505	1.7	1.70	5713.96	90.54
Junc 6	5501	2.4	2.40	5712.69	91.72
Junc 7	5500	0	0.00	5711.64	91.70
Junc 8	5500	7.3	7.30	5711.04	91.44
Junc 9	5498.75	2.3	2.30	5710.21	91.62
Junc 10	5495.5	2.3	2.30	5709.43	92.69
Junc 11	5492.25	1503.9	1503.90	5708.28	93.61
Junc 12	5494.25	2.8	2.80	5709.87	93.43
Junc 13	5494.5	2.9	2.90	5710.71	93.68
Junc 14	5512	0	0.00	5713.21	87.18
Junc 16	5494	8.8	8.80	5710.74	93.91
Junc 17	5494.5	8.8	8.80	5710.74	93.69
Junc 18	5492	25.4	25.40	5710.74	94.78
Junc 19	5495	2.9	2.90	5710.75	93.49

Fire Flow + MDD

Node ID	Elevation ft	Base Demand GPM	Demand GPM	Head ft	Pressure psi
Junc 20	5499.25	1066.6	1066.60	5710.95	91.73
Junc 21	5504.5	53.2	53.20	5716.33	91.79
Junc SDH	5504	0	0.00	5719.86	93.53
Resvr PIC	5722.65	#N/A	-2701.40	5722.65	0.00

Fire Flow + MDD

Network Table - Links

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 3	227.41	12	150	2701.40	7.66
Pipe 4	235.78	8	150	990.08	6.32
Pipe 5	109.80	8	150	986.28	6.30
Pipe 6	85.63	8	150	983.18	6.28
Pipe 7	93.83	8	150	981.48	6.26
Pipe 8	77.84	8	150	979.08	6.25
Pipe 9	92.60	8	150	660.28	4.21
Pipe 10	130.70	8	150	652.98	4.17
Pipe 11	123.32	8	150	650.68	4.15
Pipe 12	182.32	8	150	648.38	4.14
Pipe 13	151.59	8	150	-855.52	5.46
Pipe 14	79.48	8	150	-858.32	5.48
Pipe 15	729.72	8	150	793.10	5.06
Pipe 16	273.68	8	150	793.10	5.06
Pipe 17	254.43	8	150	-68.12	0.43
Pipe 18	157.73	8	150	-75.55	0.48
Pipe 19	621.12	8	150	-1.37	0.01

Fire Flow + MDD

Link ID	Length ft	Diameter in	Roughness	Flow GPM	Velocity fps
Pipe 20	154.88	8	150	-10.17	0.06
Pipe 21	619.47	8	150	-35.57	0.23
Pipe 22	760.01	8	150	-114.02	0.73
Pipe 23	297.04	8	150	915.02	5.84
Pipe 24	506.40	8	150	861.82	5.50
Pipe 25	411.34	8	150	-318.80	2.03
Valve 1	#N/A	8	#N/A	793.10	5.06

Appendix C

Sewer Demand Calculations Eagle Ridge

Commercial Average Day Flow	=	1500	gpd/acre
Residential Average Day Flow	=	68	gpd/p
Industrial Average Day Flow	=	1200	gpd/acre
Commercial Equivalent Population	=	22	per acre
Industrial Equivalent Population	=	18	per acre
Peaking Factor	=	$5/(P^{0.167})$	PF (Max. of 4, Min of 1.7)
I/I	=	AD * 0.1	gpd

Planning Area	Area (AC)	Zoning/Land Use	Design Point	Density (DU/AC)	Units	People/Unit	Average Day Flow	Equivalent Population (P)	Average Day Flow (gpd)	Peak Factor	Peak Flow (gpd)	I/I (gpd)	Total Peak Flow (gpd)	Total Peak Flow (cfs)
PA-1	7.33	Commercial	1				1,500	161	10,995	4.0	43,980	1,100	45,080	0.070
PA-2	7.83	Multi-Family	2	25	196	2.77	68	542	36,871	4.0	147,486	3,687	151,173	0.234
PA-3	3.86	Commercial	3				1,500	85	5,790	4.0	23,160	579	23,739	0.037
PA-4	4.57	Commercial	4				1,500	101	6,855	4.0	27,420	686	28,106	0.043
PA-5	10.07	Commercial	5				1,500	222	15,105	4.0	60,420	1,511	61,931	0.096
PA-6	5.59	Open Space	N/A											
Offsite 1*			EX1				1,193,455	17,116	1,193,455	3.1	3,713,629	119,345	3,832,975	5.930


*Note: Offsite flows were obtained from the Aurora One Master Utility Report. See Appendix E for excerpts.

Design Point Distribution

Eagle Ridge

Planning Area	Design Point						Flows (cfs)
	1	2	3	4	5	EX1	
PA-1	100%	100%				100%	0.070
PA-2		100%				100%	0.234
PA-3		100%	100%			100%	0.037
PA-4		100%		100%		100%	0.043
PA-5		100%		100%	100%	100%	0.096
Offsite 1*						100%	5.930
Flow Accumulation	0.070	0.480	0.037	0.139	0.096	6.410	

File: A:\HOMSP - Util Report SE2 Sewer Node Link.dwg Path: P:\Colorado\Aurora\Equity Ventures\22-064-023 Hogan & Picadilly Aurora One Master Plan\2 Drawings\ Plotted by: Ryan Date: 27-May-24 11:36:18am




LEGEND

- PROPERTY LINE 
- SANITARY MAIN 
- SANITARY NODE 
- SANITARY LINK/PIPE 

APPROVED FOR ONE YEAR FROM THIS DATE

AURORA WATER - UTILITIES DIVISION _____ DATE _____



Sewer Summary Table

Eagle Ridge

	Design Point					
	1	2	3	4	5	EX1
Pipe Slope (%)	1.00%	1.00%	1.00%	0.75%	0.75%	0.43%
Ave. Day Loading (cfs)	0.017	0.057	0.009	0.011	0.023	1.85
Population	161	542	85	101	222	17116
Peak Factor	4	4	4	4	4	3.1
Peak Loading (cfs)	0.070	0.234	0.037	0.043	0.096	6.41
Percent full (%)	14%	42%	12%	25%	20%	20%

 Project Description

File Name SSA PEAK 052724.SPF

 Analysis Options

Flow Units cfs
 Link Routing Method Kinematic Wave
 Storage Node Exfiltration.. None
 Starting Date MAY-27-2024 00:00:00
 Ending Date MAY-28-2024 00:00:00
 Report Time Step 00:05:00

 Element Count

Number of subbasins 0
 Number of nodes 15
 Number of links 14

 Node Summary

Node ID	Element Type	Invert Elevation ft	Maximum Elev. ft	Ponded Area ft ²	External Inflow
4 -DP1	JUNCTION	5495.11	5508.45	0.00	Yes
5	JUNCTION	5493.68	5510.51	0.00	
6	JUNCTION	5491.42	5506.25	0.00	
7	JUNCTION	5489.07	5498.95	0.00	
8 -DP3	JUNCTION	5495.93	5497.62	0.00	Yes
9	JUNCTION	5492.55	5496.01	0.00	
10 -DP2	JUNCTION	5484.72	5499.35	0.00	Yes
11	JUNCTION	5481.16	5499.19	0.00	
12 -DP4	JUNCTION	5487.75	5496.30	0.00	Yes
13 -DP5	JUNCTION	5490.94	5494.43	0.00	Yes
14	JUNCTION	5476.65	5493.09	0.00	
15	JUNCTION	5485.69	5509.96	0.00	Yes
16	JUNCTION	5481.95	5500.93	0.00	
17	JUNCTION	5479.28	5495.84	0.00	
Out-1EXA	OUTFALL	5473.92	5477.42	0.00	

 Link Summary

Link ID	From Node	To Node	Element Type	Length ft	Slope %	Manning's Roughness
2 -DP1	4	5	CONDUIT	113.0	1.0000	0.0120
3	5	6	CONDUIT	205.3	1.0000	0.0120
4 (1)	6	7	CONDUIT	205.3	1.0000	0.0120
4 (2) -DP3	8	9	CONDUIT	318.1	1.0000	0.0120
4 (3)	9	7	CONDUIT	318.1	1.0000	0.0120
4 (4)	7	10	CONDUIT	414.9	1.0000	0.0120
4 (5) -DP2	10	11	CONDUIT	122.3	1.0000	0.0120
4 (6) -DP4	12	10	CONDUIT	377.2	0.7500	0.0120
4 (7) -DP5	13	12	CONDUIT	397.8	0.7500	0.0120
EXA	14	Out-1EXA	CONDUIT	607.7	0.4500	0.0120
EXB	17	14	CONDUIT	596.8	0.4407	0.0120
EXC	11	17	CONDUIT	413.8	0.4314	0.0120
EXD	16	11	CONDUIT	182.1	0.4310	0.0120
EXE	15	16	CONDUIT	520.5	0.7089	0.0120

 Cross Section Summary

Link ID	Shape	Depth/ Diameter ft	Width ft	No. of Barrels	Cross Sectional Area ft ²	Full Flow Hydraulic Radius ft	Design Flow Capacity cfs
2 -DP1	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31

3	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (1)	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (2) -DP3	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (3)	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (4)	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (5) -DP2	CIRCULAR	0.67	0.67	1	0.35	0.17	1.31
4 (6) -DP4	CIRCULAR	0.67	0.67	1	0.35	0.17	1.13
4 (7) -DP5	CIRCULAR	0.67	0.67	1	0.35	0.17	1.13
EXA	CIRCULAR	3.50	3.50	1	9.62	0.88	73.12
EXB	CIRCULAR	3.50	3.50	1	9.62	0.88	72.35
EXC	CIRCULAR	3.50	3.50	1	9.62	0.88	71.59
EXD	CIRCULAR	3.50	3.50	1	9.62	0.88	71.55
EXE	CIRCULAR	3.50	3.50	1	9.62	0.88	91.77

```

*****
Flow Routing Continuity
*****
Volume      Volume
acre-ft     M gallons
-----
External Inflow ..... 0.000      0.000
External Outflow ..... 12.651     4.123
Initial Stored Volume .... 0.000      0.000
Final Stored Volume ..... 0.073      0.024
Continuity Error (%) ..... -0.001

```

```

*****
Node Depth Summary
*****

```

Node ID	Average Depth Attained ft	Maximum Depth Attained ft	Maximum HGL Attained ft	Time of Max Occurrence days hh:mm	Total Flooded Volume acre-in	Total Time Flooded minutes	Retention Time hh:mm:ss
4 -DP1	0.10	0.10	5495.21	0 00:00	0	0	0:00:00
5	0.40	0.40	5494.08	0 00:14	0	0	0:00:00
6	0.30	0.30	5491.73	0 00:28	0	0	0:00:00
7	0.40	0.40	5489.48	0 00:31	0	0	0:00:00
8 -DP3	0.08	0.08	5496.01	0 00:00	0	0	0:00:00
9	0.28	0.28	5492.83	0 00:49	0	0	0:00:00
10 -DP2	0.36	0.36	5485.08	0 00:56	0	0	0:00:00
11	2.61	2.61	5483.78	0 00:55	0	0	0:00:00
12 -DP4	0.33	0.33	5488.08	0 00:53	0	0	0:00:00
13 -DP5	0.13	0.13	5491.07	0 00:00	0	0	0:00:00
14	0.70	0.70	5477.35	0 00:58	0	0	0:00:00
15	0.61	0.61	5486.30	0 00:00	0	0	0:00:00
16	0.68	0.68	5482.63	0 00:26	0	0	0:00:00
17	0.81	0.81	5480.09	0 00:57	0	0	0:00:00
Out-1EXA	0.70	0.70	5474.62	0 00:58	0	0	0:00:00

```

*****
Node Flow Summary
*****

```

Node ID	Element Type	Maximum Lateral Inflow cfs	Peak Inflow cfs	Time of Peak Inflow Occurrence days hh:mm	Maximum Flooding Overflow cfs	Time of Peak Flooding Occurrence days hh:mm
4 -DP1	JUNCTION	0.07	0.07	0 00:00	0.00	
5	JUNCTION	0.00	0.07	0 00:15	0.00	
6	JUNCTION	0.00	0.07	0 00:28	0.00	
7	JUNCTION	0.00	0.11	0 00:54	0.00	
8 -DP3	JUNCTION	0.04	0.04	0 00:00	0.00	
9	JUNCTION	0.00	0.04	0 00:49	0.00	
10 -DP2	JUNCTION	0.23	0.48	0 00:57	0.00	
11	JUNCTION	0.00	6.41	0 00:57	0.00	
12 -DP4	JUNCTION	0.04	0.14	0 00:53	0.00	
13 -DP5	JUNCTION	0.10	0.10	0 00:00	0.00	
14	JUNCTION	0.00	6.41	0 00:58	0.00	
15	JUNCTION	5.93	5.93	0 00:00	0.00	
16	JUNCTION	0.00	5.93	0 00:26	0.00	
17	JUNCTION	0.00	6.41	0 00:57	0.00	
Out-1EXA	OUTFALL	0.00	6.41	0 00:59	0.00	

```

*****
Outfall Loading Summary
*****

```

Outfall Node ID	Flow Frequency (%)	Average Flow cfs	Peak Inflow cfs
Out-1EXA	99.69	6.40	6.41
System	99.69	6.40	6.41

Link Flow Summary

Link ID Reported Condition	Element Type	Time of Peak Flow Occurrence days hh:mm	Maximum Velocity Attained ft/sec	Length Factor	Peak Flow during Analysis cfs	Design Flow Capacity cfs	Ratio of Maximum /Design Flow	Ratio of Maximum Flow Depth	Total Time Surcharged minutes
2 -DP1 Calculated	CONDUIT	0 00:15	1.99	1.00	0.07	1.31	0.05	0.16	0
3 Calculated	CONDUIT	0 00:28	1.99	1.00	0.07	1.31	0.05	0.16	0
4 (1) Calculated	CONDUIT	0 00:31	1.99	1.00	0.07	1.31	0.05	0.16	0
4 (2) -DP3 Calculated	CONDUIT	0 00:49	1.65	1.00	0.04	1.31	0.03	0.12	0
4 (3) Calculated	CONDUIT	0 00:54	1.65	1.00	0.04	1.31	0.03	0.12	0
4 (4) Calculated	CONDUIT	0 00:57	2.26	1.00	0.11	1.31	0.08	0.19	0
4 (5) -DP2 Calculated	CONDUIT	0 00:57	3.46	1.00	0.48	1.31	0.37	0.42	0
4 (6) -DP4 Calculated	CONDUIT	0 00:56	2.20	1.00	0.14	1.13	0.12	0.24	0
4 (7) -DP5 Calculated	CONDUIT	0 00:54	1.98	1.00	0.10	1.13	0.08	0.20	0
EXA Calculated	CONDUIT	0 00:59	4.68	1.00	6.41	73.12	0.09	0.20	0
EXB Calculated	CONDUIT	0 00:58	4.65	1.00	6.41	72.35	0.09	0.20	0
EXC Calculated	CONDUIT	0 00:57	4.61	1.00	6.41	71.59	0.09	0.20	0
EXD Calculated	CONDUIT	0 00:27	4.50	1.00	5.93	71.55	0.08	0.19	0
EXE Calculated	CONDUIT	0 00:26	5.34	1.00	5.93	91.77	0.06	0.17	0


Highest Flow Instability Indexes

All links are stable.

Analysis began on: Mon May 27 12:49:45 2024
Analysis ended on: Mon May 27 12:49:46 2024
Total elapsed time: 00:00:01


Appendix D

EAGLE RIDGE OPEN SPACE, CIRCULATION, AND NEIGHBORHOOD PLAN



Legend

- Project Boundary
- Open Space
- 25' Special Landscape Buffer
- Development Restriction Area
- Planning Area Boundary
- 1/4 Mile Eagle Nest Site Buffer
- Future Proposed Boundary Fence
- Right of Way
- Airport Noise Boundary
- Mainstreet
- * Primary Entryway
- * Secondary Entryway
- ➔ Access to Roadway Network
- ➔ Primary Access
- ➔ Future Internal Connection
- * Detention Pond (100% drains in 24 hours)
- * Proposed Plaza Space



1. No transit stops are anticipated.

2. Active construction will be avoided during the breeding season for bald eagles (December 1 - July 31) within the identified development restriction zone. Laydown and staging areas will also be located outside of the development restriction zone.

3. Each developed PA will have two points of access. Final details will be provided at the time of the site plan.

4. The boundary fence shall be completed along PA-2 and PA-4 prior to the first CO for PA-2. The boundary fence along PA-5 shall be completed prior to the first CO of PA-5.

5. Per CPW letter dated 8/19/22, the detention basin with vegetation can be constructed within the 1/8 mile buffer of the eagle's nest. Once constructed, human activity in this area will be limited.

6. The Bald Eagle Guidelines published by Colorado Parks and Wildlife clearly note that no Surface Occupancy (NSO) may occur within a 1/4 mile radius of active nests. Additionally, no permitted authorized, or human encroachment activities within 1/2 mile radius of active nest sites from December 1 through July 31 (with the recommendation to extend it fledglings are still present in the nest).

Appendix E

Sanitary Sewer Flows for Aurora One

SANITARY FLOW SUMMARY (LOCAL)

PLANNING AREA	ZONING	ZONING TYPE	Design Point	AVG. DAY FLOW	DENSITY	TOTAL AREA	EQUIVALENT TOTAL POPULATION (P)	LOCAL AVG. FLOW
					DU/AC	ACRES		GPD
BASIN A								
1	PA-1	Commercial	1	1,500		5.90	88	8,850
Subtotal Basin A							88	8,850
BASIN B								
11	PA-11	Commercial	2	1,500		6.93	103	10,395
13 - West	PA-13	Single Family Attached Residential	2	68	12	4.13	137	9,335
Subtotal Basin B							240	19,730
BASIN C								
13 - East	PA-13	Single Family Attached Residential	5	68	12	22.64	753	51,174
14	PA-14	Commercial	5	1,500		3.43	51	5,145
Subtotal Basin C							803	56,319
BASIN D								
2	PA-2	Commercial	4	1,500		6.36	94	9,540
3	PA-3	Neighborhood Park	3	1,200		6.20	74	7,440
4-West	PA-4	Single-Family Attached Residential	3	68	12	2.80	93	6,329
8-West	PA-8	Commercial	4	1,500		6.61	98	9,915
9	PA-9	Commercial	4	1,500		8.19	122	12,285
10-South	PA-10	MF Residential	3	68	25	1.10	76	5,180
Subtotal Basin D							557	50,689
BASIN E								
7-South	PA-7	Neighborhood Park	3	1,200		4.03	48	4,836
8-East	PA-8	Commercial	3	1,500		3.54	53	5,310
10-North	PA-10	MF Residential	3	68	25	11.21	776	52,788
Subtotal Basin E							877	62,934

Sanitary Sewer Flows for Aurora One

SANITARY FLOW SUMMARY (LOCAL)

PLANNING AREA	ZONING	ZONING TYPE	Design Point	AVG. DAY FLOW	DENSITY	TOTAL AREA	EQUIVALENT TOTAL POPULATION (P)	LOCAL AVG. FLOW
					DU/AC	ACRES		GPD
BASIN F								
4-East	PA-4	Single-Family Attached Residential	3	68	12	19.89	661	44,958
5-R	PA-5	MF Residential	3	68	25	6.49	449	30,561
5-C	PA-5	Commercial	3	1,500		6.49	96	9,735
7-North	PA-7	Neighborhood Park	3	1,200		4.43	53	5,316
Subtotal Basin F							1,260	90,570
Offsite								
Horizon Uptown*		Retail/Commerical/Residential	6				13,291	904,363
Subtotal Offsite							13,291	904,363

$$Avg\ Flow = AREA\ (AC) \times AVG.\ DAY\ FLOW\ \left(\frac{GDP}{AC}\right) =$$

$$Peak\ Flow = Peak\ Factor \times Avg\ Flow =$$

$$l/l = Avg\ Flow \times 0.1 =$$

$$Peak\ Factor\ (PF) = \frac{5}{P^{0.167}} =$$

where P=Population in thousands

$$TOTAL\ AVERAGE\ FLOW = Avg\ Flow + (Avg\ Flow \times 0.1)$$

$$TOTAL\ PEAK\ FLOW = Peak\ Flow(Avg\ Flow \times 0.1) =$$

Zoning	Average Day
Commercial	1500 gpd/acre
Residential	68 gpd/pp
People per unit	2.77

*Equivalent Total Population and Local Average Flow Derived from the approved Horizon Uptown City Center Draft Master Utilities Report prepared by Matrix Design Group, dated September 19, 2018. COA #218158

Flow and populations taken are the cumulative amounts at Horizon design point 7 less the assumed "Offsite South" amounts from the Horizon Report.

Sanitary Calculations for Aurora One

City of Aurora Standards	
City of Aurora Density	<u>2.77</u> people / unit
Residential average demand:	<u>68</u> gal / person / day

Design Point	Basins	Average Daily Flow (GPD)	Population	Used Peaking Factor	Peak Flow	I+I	Peak Flow + (I+I) (gpd)	Peak flow (q) (cfs)	Pipe Size (in)	Minimum Pipe Slope (%)	Q _{full} (cfs)	Full Flow Capacity ¹ (%)	Q _{cap.} (cfs)	q/Q _{full} (%)
1	A	8,850	88	4.0	35,400	885	36,285	0.06	8	0.50%	1.01	75%	0.76	5.6%
2	B	19,730	240	4.0	78,920	1,973	80,893	0.13	8	0.50%	1.01	75%	0.76	12.4%
3	E + F	153,504	2136	4.0	614,016	15,350	629,367	0.97	10	0.50%	1.83	75%	1.37	53.2%
4	D + E + F	204,193	2694	4.0	816,771	20,419	837,191	1.30	12	0.50%	2.98	75%	2.23	43.5%
5	C + D + E + F	260,512	3497	4.0	1,042,046	26,051	1,068,097	1.65	12	0.50%	2.98	75%	2.23	55.5%
6	A + B + C + D + E + F + Offsite	1,193,455	17116	3.1	3,713,629	119,345	3,832,975	5.93	18	0.40%	7.85	80%	6.28	75.5%