

DRIVE LANE A - SITE PLAN FOR INFRASTRUCTURE

CITADEL ON COLFAX SUBDIVISION FILING NO. 1 & 2 CITY OF AURORA, COUNTY OF ARAPAHOE, STATE OF COLORADO

The site plan will not be approved by public works until the preliminary drainage letter/report is approved

Please remove AutoCad SHX text items in the comment section. Please flatten to reduce select-ability of the items.

Noted. The PDL has been resubmitted for signature.

Sheets have been flattened.

LIST OF CONTACTS

DEVELOPER/OWNER

COLFAX & SABLE, LLC
14800 E. COLFAX AVE.,
AURORA, CO 80011
TEL: (720) 519-6577
CONTACT: JAZZMINE CLIFTON
EMAIL: JAZZMINE@STRATEGICSTORAGEPARTNERS.COM

CIVIL ENGINEER

GALLOWAY & COMPANY, INC.
6162 S. WILLOW DRIVE, SUITE 320
GREENWOOD VILLAGE, COLORADO 80111
TEL: (303) 770-8884
FAX: (303) 770-3636
CONTACT: SCOTT M. BROWN, P.E.
EMAIL: SCOTTBROWN@GALLOWAYUS.COM

LANDSCAPE ARCHITECT


GALLOWAY & COMPANY, INC.
6162 S. WILLOW DRIVE, SUITE 320
GREENWOOD VILLAGE, COLORADO 80111
TEL: (303) 770-8884
FAX: (303) 770-3636
CONTACT: TIM NELSON
EMAIL: TIMNELSON@GALLOWAYUS.COM

SITE DATA TABLE

	SF	AC	%
HARD SURFACE AREA	8,875	0.20	79.5%
LANDSCAPE AREA	2,290	0.05	20.5
PRESENT ZONING CLASSIFICATION	MU-C		


CITY OF AURORA SITE PLAN NOTES

- THE DEVELOPER, HIS SUCCESSORS AND ASSIGNS SHALL BE RESPONSIBLE FOR INSTALLATION, MAINTENANCE AND REPLACEMENT OF FIRE LANE EASEMENTS CONSTRUCTED WITHIN THIS SITE USING ALTERNATIVE SURFACING MATERIALS SUCH AS, BUT NOT LIMITED TO: GRASSPAVE, GRASS CRETE, RITTER RINGS, INVISIBLE STRUCTURES UTILIZED ONLY FOR EMERGENCY VEHICLE ACCESS USE. THIS AGREEMENT WILL INCLUDE SNOW REMOVAL TO ENSURE EMERGENCY ACCESS IS AVAILABLE AT ALL TIMES IF THE ABOVE CONDITIONS ARE NOT MET. THE OWNERS, HIS SUCCESSORS AND ASSIGNS SHALL BE REQUIRED BY ORDER NOTICE FROM THE AURORA FIRE DEPARTMENT TO REMOVE THE INVISIBLE STRUCTURE AND REPLACE IT WITH AN ASPHALT OR CONCRETE ROAD SURFACE THAT MEETS THE CONSTRUCTION REQUIREMENTS OF THE PUBLIC WORKS DEPARTMENT FIRE LANE STANDARDS AND BE SHOWN IN DETAIL WITHIN THE CIVIL PLANS.
- THE APPLICANT HAS THE OBLIGATION TO COMPLY WITH ALL APPLICABLE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT.
- ARCHITECTURAL FEATURES (I.E. BAY WINDOWS, FIREPLACES, ROOF OVERHANG, GUTTERS, EAVES, FOUNDATIONS, FOOTINGS, CANTILEVERED WALLS, ETC.,) ARE NOT ALLOWED TO ENCROACH INTO ANY EASEMENT OR FIRE LANE.
- THE APPROVAL OF THIS DOCUMENT DOES NOT CONSTITUTE FINAL APPROVAL OF GRADING, DRAINAGE, UTILITY, PUBLIC IMPROVEMENTS AND BUILDING PLANS. CONSTRUCTION PLANS MUST BE REVIEWED AND APPROVED BY THE APPROPRIATE AGENCY PRIOR TO THE ISSUANCE OF BUILDING PERMITS.
- ALL SIGNS MUST CONFORM TO THE CITY OF AURORA SIGN CODE.
- THE METRO DISTRICT, ITS SUCCESSORS AND ASSIGNS, SHALL BE RESPONSIBLE FOR INSTALLATION, MAINTENANCE AND REPLACEMENT OF ALL LANDSCAPING MATERIALS SHOWN OR INDICATED ON THE APPROVED SITE PLAN OR LANDSCAPE PLAN ON FILE IN THE PLANNING DEPARTMENT. ALL LANDSCAPING WILL BE INSTALLED PRIOR TO ISSUANCE OF CERTIFICATE OF OCCUPANCY. THE METRO DISTRICT IS RESPONSIBLE FOR THE LANDSCAPING WITHIN TRACT E ONLY. ADJACENT LOTS ARE RESPONSIBLE FOR ALL OTHER LANDSCAPING.
- ALL CROSSINGS OR ENCROACHMENTS INTO EASEMENTS AND RIGHTS-OF-WAY OWNED BY THE CITY OF AURORA ("CITY") IDENTIFIED AS BEING PRIVATELY-OWNED AND MAINTAINED HEREIN ARE ACKNOWLEDGED BY THE UNDERSIGNED AS BEING SUBJECT TO CITY'S USE AND OCCUPANCY OF SAID EASEMENTS OR RIGHTS-OF-WAY. THE UNDERSIGNED, ITS SUCCESSORS AND ASSIGNS, FURTHER AGREES TO REMOVE, REPAIR, REPLACE, RELOCATE, MODIFY OR OTHERWISE ADJUST SAID CROSSINGS OR ENCROACHMENTS UPON REQUEST FROM THE CITY AND AT NO EXPENSE TO THE CITY. THE CITY RESERVES THE RIGHT TO MAKE FULL USE OF THE EASEMENTS AND RIGHTS-OF-WAY AS MAY BE NECESSARY OR CONVENIENT AND THE CITY RETAINS ALL RIGHT TO OPERATE, MAINTAIN, INSTALL, REPAIR, REMOVE, OR RELOCATE ANY CITY FACILITIES LOCATED WITHIN SAID EASEMENTS AND RIGHTS-OF-WAY AT ANY TIME AND IN SUCH A MANNER AS IT DEEMS NECESSARY OR CONVENIENT.
- ALL BUILDING ADDRESS NUMBERS SHALL COMPLY WITH THE AURORA CITY CODE ORDINANCE, CHAPTER 126 - ARTICLE VII - NUMBERING OF BUILDINGS.
- NOTWITHSTANDING ANY SURFACE IMPROVEMENTS, LANDSCAPING, PLANTING OR CHANGES SHOWN IN THESE SITE OR CONSTRUCTION PLANS, OR ACTUALLY CONSTRUCTED OR PUT IN PLACE, ALL UTILITY EASEMENTS MUST REMAIN UNOBTSTRUCTED AND FULLY ACCESSIBLE ALONG THEIR ENTIRE LENGTH TO ALLOW FOR ADEQUATE MAINTENANCE EQUIPMENT. ADDITIONALLY, NO INSTALLATION, PLANTING, CHANGE IN THE SURFACE, ETC., SHALL INTERFERE WITH THE OPERATION OF THE UTILITY LINES PLACED WITHIN THE EASEMENT. BY SUBMITTING THESE SITE OR CONSTRUCTION PLANS FOR APPROVAL, THE LANDOWNER RECOGNIZES AND ACCEPTS THE TERMS, CONDITIONS AND REQUIREMENTS OF THIS NOTE.
- FINAL GRADE SHALL BE AT LEAST SIX (6) INCHES BELOW ANY EXTERIOR WOOD SIDING ON THE PREMISES.
- ALL INTERESTED PARTIES ARE HEREBY ALERTED THAT THIS SITE PLAN IS SUBJECT TO ADMINISTRATIVE CHANGES AND AS SHOWN ON THE ORIGINAL SITE PLAN ON FILE IN THE AURORA CITY PLANNING OFFICE AT THE MUNICIPAL BUILDING. A COPY OF THE OFFICIAL CURRENT PLAN MAY BE PURCHASED THERE. LIKEWISE, SITE PLANS ARE REQUIRED TO AGREE WITH THE APPROVED SUBDIVISION PLAT OF RECORD AT THE TIME OF A BUILDING PERMIT, AND IF NOT, MUST BE AMENDED TO AGREE WITH THE PLAT AS NEEDED, OR VICE VERSA.
- ERRORS IN APPROVED SITE PLANS RESULTING FROM COMPUTATIONS OR INCONSISTENCIES IN THE DRAWINGS MADE BY THE APPLICANT ARE THE RESPONSIBILITY OF THE PROPERTY OWNER OF RECORD. WHERE FOUND, THE CURRENT MINIMUM CODE REQUIREMENTS WILL APPLY AT THE TIME OF BUILDING PERMIT. PLEASE BE SURE THAT ALL PLAN COMPUTATIONS ARE CORRECT.
- ALL REPRESENTATIONS AND COMMITMENTS MADE BY APPLICANTS AND PROPERTY OWNERS AT PUBLIC HEARINGS REGARDING THIS PLAN ARE BINDING UPON THE APPLICANT, PROPERTY OWNER, AND ITS HEIRS, SUCCESSORS, AND ASSIGNS.
- RIGHT OF WAY FOR INGRESS AND EGRESS FOR SERVICE AND EMERGENCY VEHICLES IS GRANTED OVER, ACROSS, ON AND THROUGH ANY AND ALL PRIVATE ROADS AND WAYS NOW OR HEREAFTER ESTABLISHED ON THE DESCRIBED PROPERTY, AND THE SAME ARE HEREBY DESIGNATED AS "SERVICE/EMERGENCY AND UTILITY EASEMENT AND SHALL BE POSTED "NO PARKING - FIRE LANE".
- ACCESSIBLE EXTERIOR ROUTES " SHALL BE PROVIDED FROM PUBLIC TRANSPORTATION STOPS, ACCESSIBLE PARKING AND ACCESSIBLE PASSENGER LOADING ZONES AND PUBLIC SIDEWALKS TO 60% OF THE ACCESSIBLE BUILDING ENTRANCE THEY SERVE. THE ACCESSIBLE ROUTE BETWEEN ACCESSIBLE PARKING ACCESSIBLE BUILDING ENTRANCES SHALL BE THE MOST PRACTICAL DIRECT ROUTE. THE ACCESSIBLE ROUTE MUST BE LOCATED WITHIN A SIDEWALK. NO SLOPE ALONG THE ROUTE MAY EXCEED 1:20 WITHOUT PROVIDING A RAMP WITH A MAXIMUM SLOPE OF 1:12 AND HANDRAILS. CROSSWALKS ALONG THIS ROUTE SHALL BE WIDE ENOUGH TO WHOLLY CONTAIN THE CURB RAMP WITH A MINIMUM WIDTH OF 36" AND SHALL BE PAINTED WITH WHITE STRIPES. THE CITY OF AURORA ENFORCES HANDICAPPED ACCESSIBILITY REQUIREMENTS BASED ON THE 2015 INTERNATIONAL BUILDING CODE, CHAPTER 11 AND THE ICC A117.1-2009.
- IN LOCATIONS WHERE UTILITY EASEMENTS OVERLAP DRAINAGE EASEMENTS, ONLY SUBSURFACE UTILITIES SHALL BE PERMITTED WITHIN THE PORTION OF THE UTILITY EASEMENT THAT OVERLAPS THE DRAINAGE EASEMENT. INSTALLATION OF ABOVE GROUND UTILITIES WITHIN A DRAINAGE EASEMENT REQUIRES PRIOR WRITTEN APPROVAL BY THE CITY ENGINEER



VICINITY MAP

SCALE: 1" = 500'



CITADEL MASTER SITE PLAN KEY MAP

SCALE: 1"=400'

There are some easement issues and some License Agreement issues. See the comments on the document(s). Contact Andy Niquette (aniquett@auroragov.org) for the easement concerns and Contact Grace Gray (ggray@auroragov.org) for the License Agreement concerns. Please note that the site plan cannot be approved until all the items needed are submitted, fully reviewed and ready to record.

Please see responses on the following pages.

AMENDMENTS

LEGAL DESCRIPTION

CITADEL ON COLFAX SUBDIVISION FILING NOS. 1 & 2
CITY OF AURORA, COUNTY OF ARAPAHOE, STATE OF COLORADO

LOCATED IN THE NORTHEAST QUARTER SECTION 6; TOWNSHIP 4 SOUTH;
RANGE 66 WEST OF THE 6TH PRINCIPAL MERIDIAN
CITY OF AURORA, COUNTY OF ARAPAHOE, STATE OF COLORADO

SIGNATURE BLOCK

THIS SITE PLAN AND ANY AMENDMENTS HERETO, UPON APPROVAL BY THE CITY OF AURORA AND RECORDING, SHALL BE BINDING UPON THE APPLICANTS THEREFORE, THEIR SUCCESSORS AND ASSIGNS. THIS PLAN SHALL LIMIT AND CONTROL THE ISSUANCE AND VALIDITY OF ALL BUILDING PERMITS, AND SHALL RESTRICT AND LIMIT THE CONSTRUCTION, LOCATION, USE, OCCUPANCY AND OPERATION OF ALL LAND AND STRUCTURES WITHIN THIS PLAN TO ALL CONDITIONS, REQUIREMENTS, LOCATIONS AND LIMITATIONS SET FORTH HEREIN. ABANDONMENT, WITHDRAWAL OR AMENDMENT OF THIS PLAN MAY BE PERMITTED ONLY UPON APPROVAL OF THE CITY OF AURORA.

IN WITNESS THEREOF, _____ HAS CAUSED THESE
PRESENTS TO BE EXECUTED THIS _____ DAY OF _____ AD, 2021.

BY: _____
NAME: _____
ITS: _____

STATE OF _____)
COUNTY OF _____) SS

THE FOREGOING INSTRUMENT WAS ACKNOWLEDGED BEFORE ME THIS _____ DAY OF _____ AD, 2021.

BY _____
(PRINCIPALS OR OWNERS)

WITNESS MY HAND AND OFFICIAL SEAL

NOTARY SEAL

(NOTARY PUBLIC)

MY COMMISSION EXPIRES _____

NOTARY BUSINESS ADDRESS: _____

CITY OF AURORA APPROVAL

CITY ATTORNEY: _____ DATE: _____

PLANNING DIRECTOR: _____ DATE: _____

PLANNING COMMISSION: _____ DATE: _____
(CHAIRPERSON)

CITY COUNCIL: _____ DATE: _____
(MAYOR)

ATTEST: _____ DATE: _____
(CITY CLERK)

DATABASE APPROVAL DATE: _____

RECORDER'S CERTIFICATE:

ACCEPTED FOR FILING IN THE OFFICE OF THE CLERK AND RECORDER OF

COLORADO AT _____ O'CLOCK _____ M, THIS _____ DAY OF _____ AD, 2021

CLERK AND RECORDER: _____ DEPUTY: _____

Galloway

6162 S. Willow Drive, Suite 320
Greenwood Village, CO 80111
303.770.8884
GallowayUS.com



CITADEL ON COLFAX SUBDIVISION FILING NO. 1
LOT 2, BLOCK 8 - DRIVE LANE A (PRIVATE)
INFRASTRUCTURE SITE PLAN




EAST COLFAX AVE. / ALTURA BLVD.
AURORA, CO

#	Date	Issue / Description	Init.
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			

Project No:	NCP001
Drawn By:	JRC
Checked By:	SMB
Date:	2/5/2021

COVER SHEET

© 2021 Galloway Engineering, Inc. All rights reserved. This drawing is the property of Galloway Engineering, Inc. and is not to be reproduced or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without the prior written permission of Galloway Engineering, Inc.



- SITE LEGEND**
- EXISTING PROPERTY LINE
 - EXISTING EASEMENT
 - PROPOSED EASEMENT BY ADJACENT PROPERTY OWNER
 - EXISTING CURB AND GUTTER
 - PROPOSED CURB AND GUTTER
 - PROPOSED CURB AND GUTTER BY ADJACENT PROPERTY OWNER
 - EXISTING SIDEWALK
 - PROPOSED SIDEWALK
 - PROPOSED ROAD CENTERLINE
 - PROPOSED SIDEWALK BY ADJACENT PROPERTY OWNER
 - SITE SIGN

- SCHEDULE NOTES**
- EXISTING ACCESS AND UTILITY EASEMENT REC. D8169331 AND D9054873
 - EXISTING ACCESS AND UTILITY EASEMENT REC. D8169331 AND D9054873
 - EXISTING CURB
 - EXISTING CURB AND GUTTER TO BE REMOVED
 - EXISTING SIDEWALK, SIZE PER PLAN
 - EXISTING ACCESSIBLE RAMP
 - EXISTING ACCESSIBLE RAMP TO BE REMOVED
 - EXISTING RETAINING WALL
 - PROPOSED ACCESS AND UTILITY EASEMENT BY ADJACENT PROPERTY OWNER (Lot 1, Block 1, DA 1422-13)
 - PROPOSED CURB AND GUTTER BY ADJACENT PROPERTY OWNER.
 - PROPOSED SIDEWALK BY ADJACENT PROPERTY OWNER. SIZE PER PLAN.
 - PROPOSED STOP SIGN BY ADJACENT PROPERTY OWNER.
 - PROPOSED ACCESSIBLE RAMP BY ADJACENT PROPERTY OWNER
 - PROPOSED STREET LIGHT BY ADJACENT PROPERTY OWNER.
 - PROPOSED VERTICAL CURB AND GUTTER
 - PROPOSED ACCESSIBLE RAMP
 - PROPOSED 8' CROSS PAN
 - PROPOSED STOP SIGN
 - EXISTING FENCE
 - EXISTING UTILITY EASEMENT REC. D8169331
 - PROPOSED GUARDRAIL

BASIS OF BEARINGS

THE NORTH LINE OF LOT 1, BLOCK 1, MONTEREY POINTE SUBDIVISION FILING NO. 2 IS ASSUMED TO BEAR SOUTH 89°58'13" EAST AND MONUMENTED ON BOTH ENDS BY A NO. 5 REBAR WITH A YELLOW PLASTIC CAP STAMPED, "PLS 38445".


BENCHMARK

SOURCE BM: CITY OF AURORA BENCHMARK G-036B ELEV=5392.18 (NAVD 88) A 3" BRASS CAP STAMPED, "CITY OF AURORA G-036B" IN THE SOUTHWESTERLY CORNER OF A CONCRETE INLET STRUCTURE LOCATED APPROXIMATELY 134 FEET SOUTH OF THE CENTERLINE OF EAST COLFAX AVENUE AND APPROXIMATELY 930 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE003

SITE BM: CITY OF AURORA BENCHMARK 037 ELEV=5405.22 A CHISELED SQUARE AT THE SOUTHEAST CORNER OF A CONCRETE INLET STRUCTURE APPROXIMATELY 90 FEET SOUTH OF THE CENTERLINE OF COLFAX AVENUE AND APPROXIMATELY 1420 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE004

- CAUTION - NOTICE TO CONTRACTOR**
- ALL UTILITY LOCATIONS SHOWN ARE BASED ON MAPS PROVIDED BY THE APPROPRIATE UTILITY COMPANY AND FIELD SURFACE EVIDENCE AT THE TIME OF SURVEY AND IS TO BE CONSIDERED AN APPROXIMATE LOCATION ONLY. IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE FIELD LOCATION OF ALL UTILITIES, PUBLIC OR PRIVATE, WHETHER SHOWN ON THE PLANS OR NOT, PRIOR TO CONSTRUCTION. REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO CONSTRUCTION.
 - WHERE A PROPOSED UTILITY CROSSES AN EXISTING UTILITY, IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE HORIZONTAL AND VERTICAL LOCATION OF SUCH EXISTING UTILITY, EITHER THROUGH POT-HOLING OR ALTERNATIVE METHOD. REPORT INFORMATION TO THE ENGINEER PRIOR TO CONSTRUCTION.

- SITE PLAN NOTES**
- ALL ADJACENT PROPERTIES ARE ZONED AS MU-C.
 - SIGNS SHALL BE FURNISHED AND INSTALLED PER THE MOST CURRENT EDITIONS OF THE MANUAL ON UNIFORM TRAFFIC CONTROL DEVICES (MUTCD) AND CITY STANDARDS, AND SHOWN ON THE SIGNAGE AND STRIPING PLAN FOR THE DEVELOPMENT.
 - ALL STREETS SHALL BE ASPHALT AND ALL SIDEWALKS WILL BE CONCRETE.



CITADEL ON COLFAX SUBDIVISION FILING NO. 1
LOT 2, BLOCK 8 - DRIVE LANE A
INFRASTRUCTURE SITE PLAN




EAST COLFAX AVE. / ALTURA BLVD
AURORA, CO

#	Date	Issue / Description	Init.
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			

Project No: NCP001
Drawn By: JRC
Checked By: SMB
Date: 2/5/2021

SITE PLAN

\\nautilus\corporate\personnel\2020\05\17_Aurora_CO_Colfax and Sable\042021\Perth\Project\Infrastructure - CITADEL ON COLFAX - CITADEL ON COLFAX SUBDIVISION FILING NO. 1.dwg, 25/05/2021



GRADING LEGEND

- EXISTING PROPERTY LINE
- EXISTING EASEMENT
- PROPOSED EASEMENT BY ADJACENT PROPERTY OWNER
- EXISTING CURB AND GUTTER
- PROPOSED CURB AND GUTTER
- PROPOSED CURB AND GUTTER BY ADJACENT PROPERTY OWNER
- PROPOSED SWALE
- EXISTING SIDEWALK
- PROPOSED SIDEWALK
- PROPOSED SIDEWALK BY ADJACENT PROPERTY OWNER
- EXISTING MAJOR CONTOUR
- EXISTING MINOR CONTOUR
- PROPOSED MAJOR CONTOUR
- PROPOSED MINOR CONTOUR
- PROPOSED MAJOR CONTOUR BY ADJACENT PROPERTY OWNER
- PROPOSED MINOR CONTOUR BY ADJACENT PROPERTY OWNER

SCHEDULE NOTES

- 1) EXISTING ACCESS AND UTILITY EASEMENT REC. D8169331 AND D9054873
- 2) EXISTING ACCESS AND UTILITY EASEMENT TO BE VACATED BY ADJACENT PROPERTY OWNER
- 3) EXISTING STORM SEWER
- 4) PROPOSED ACCESS AND UTILITY EASEMENT BY ADJACENT PROPERTY OWNER
- 5) PROPOSED 18" RCP
- 6) PROPOSED COA 5' TYPE R INLET
- 7) PROPOSED CDOT TYPE C INLET
- 8) PROPOSED SWALE
- 9) PROPOSED STORM MANHOLE BY ADJACENT PROPERTY OWNER
- 10) PROPOSED STORM SEWER BY ADJACENT PROPERTY OWNER
- 11) EXISTING TYPE C INLET
- 12) PROPOSED STORM INLET BY ADJACENT PROPERTY OWNER
- 13) EXISTING UTILITY EASEMENT REC. D8169331

BASIS OF BEARINGS

THE NORTH LINE OF LOT 1, BLOCK 1, MONTEREY POINTE SUBDIVISION FILING NO. 2 IS ASSUMED TO BEAR SOUTH 89°58'13" EAST AND MONUMENTED ON BOTH ENDS BY A NO. 5 REBAR WITH A YELLOW PLASTIC CAP STAMPED, "PLS 38445".

BENCHMARK

SOURCE BM: CITY OF AURORA BENCHMARK G-036B ELEV=5392.18 (NAVD 88) A 3" BRASS CAP STAMPED, "CITY OF AURORA G-036B" IN THE SOUTHWESTERLY WING WALL OF A CONCRETE INLET STRUCTURE LOCATED APPROXIMATELY 134 FEET SOUTH OF THE CENTERLINE OF EAST COLFAX AVENUE AND APPROXIMATELY 930 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE003
SITE BM: CITY OF AURORA BENCHMARK 037 ELEV=5405.22 A CHISELED SQUARE AT THE SOUTHEAST CORNER OF A CONCRETE INLET STRUCTURE APPROXIMATELY 90 FEET SOUTH OF THE CENTERLINE OF COLFAX AVENUE AND APPROXIMATELY 1420 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE004


CAUTION - NOTICE TO CONTRACTOR

- 1. ALL UTILITY LOCATIONS SHOWN ARE BASED ON MAPS PROVIDED BY THE APPROPRIATE UTILITY COMPANY AND FIELD SURFACE EVIDENCE AT THE TIME OF SURVEY AND IS TO BE CONSIDERED AN APPROXIMATE LOCATION ONLY. IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE FIELD LOCATION OF ALL UTILITIES, PUBLIC OR PRIVATE, WHETHER SHOWN ON THE PLANS OR NOT, PRIOR TO CONSTRUCTION. REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO CONSTRUCTION.
- 2. WHERE A PROPOSED UTILITY CROSSES AN EXISTING UTILITY, IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE HORIZONTAL AND VERTICAL LOCATION OF SUCH EXISTING UTILITY, EITHER THROUGH POT-HOLING OR ALTERNATIVE METHOD. REPORT INFORMATION TO THE ENGINEER PRIOR TO CONSTRUCTION.



GRADING PLAN NOTES

- 1. SPOT GRADES ARE TO FLOWLINE UNLESS OTHERWISE NOTED
- 2. ALL STORM SEWER IS PRIVATE AND MAINTAINED BY THE METRO DISTRICT.



CITADEL ON COLFAX SUBDIVISION FILING NO. 1
LOT 2, BLOCK 8 - DRIVE LANE A (PRIVATE)
INFRASTRUCTURE SITE PLAN




EAST COLFAX AVE. / ALTURA BLVD.
AURORA, CO

#	Date	Issue / Description	Init.

Project No:	NCP001
Drawn By:	JRC
Checked By:	SMB
Date:	2/5/2021

GRADING PLAN

\\nas01\corporate\personnel\2020\0117 - Aurora, CO - Colfax and Sable\GIS\2020\Permit\Project\Infrastructure - CITADEL ON COLFAX - 10/19/2021 - JRC



UTILITY LEGEND

- EXISTING PROPERTY LINE
- PROPOSED PROPERTY LINE
- EXISTING EASEMENT
- PROPOSED EASEMENT
- EXISTING CURB AND GUTTER
- PROPOSED CURB AND GUTTER
- EXISTING WATER LINE
- PROPOSED WATER LINE
- EXISTING SANITARY SEWER
- PROPOSED SANITARY SEWER
- EXISTING STORM SEWER
- PROPOSED STORM SEWER
- EXISTING VALVE
- PROPOSED VALVE
- EXISTING FIRE HYDRANT
- PROPOSED FIRE HYDRANT
- PROPOSED WATER METER
- PROPOSED INLET
- PROPOSED BY OTHERS INLET
- EXISTING INLET
- EXISTING STORM MANHOLE
- EXISTING SANITARY MANHOLE

SCHEDULE NOTES

- EXISTING ACCESS AND UTILITY EASEMENT REC. D8169331 AND D9054873
- EXISTING ACCESS AND UTILITY EASEMENT TO BE VACATED BY ADJACENT PROPERTY OWNER
- EXISTING STORM INLET TO BE REMOVED AND RELOCATED BY ADJACENT PROPERTY OWNER
- EXISTING STORM PIPE TO BE REMOVED AND RELOCATED BY ADJACENT PROPERTY OWNER
- EXISTING STORM SEWER
- EXISTING SANITARY SEWER MANHOLE
- EXISTING 8" SANITARY SEWER TO BE REMOVED AND RELOCATED BY ADJACENT PROPERTY OWNER
- EXISTING FIRE HYDRANT TO BE REMOVED AND RELOCATED BY ADJACENT PROPERTY OWNER
- EXISTING 8" WATER LINE TO BE REMOVED AND RELOCATED BY ADJACENT PROPERTY OWNER
- PROPOSED ACCESS AND UTILITY EASEMENT BY ADJACENT PROPERTY OWNER
- PROPOSED STORM INLET BY ADJACENT PROPERTY OWNER
- PROPOSED STORM MANHOLE BY ADJACENT PROPERTY OWNER
- PROPOSED STORM SEWER BY ADJACENT PROPERTY OWNER
- PROPOSED RELOCATED 8" SANITARY SEWER LINE BY ADJACENT PROPERTY OWNER
- PROPOSED RELOCATED 8" WATERLINE BY ADJACENT PROPERTY OWNER
- PROPOSED FIRE HYDRANT BY ADJACENT PROPERTY OWNER
- PROPOSED COA MODIFIED TYPE R INLET
- PROPOSED STORM SEWER PIPE
- PROPOSED CDOT TYPE C INLET
- EXISTING UTILITY EASEMENT REC. D8169331

UTILITY PLAN NOTES

- ALL STORM SEWER IS PRIVATE AND MAINTAINED BY THE METRO DISTRICT.

BASIS OF BEARINGS

THE NORTH LINE OF LOT 1, BLOCK 1, MONTEREY PONTE SUBDIVISION FILING NO. 2 IS ASSUMED TO BEAR SOUTH 89°58'13" EAST AND MONUMENTED ON BOTH ENDS BY A NO. 5 REBAR WITH A YELLOW PLASTIC CAP STAMPED, "PLS 38445".

BENCHMARK

SOURCE BM: CITY OF AURORA BENCHMARK G-0368 ELEV=5392.18 (NAVD 88)
A 3" BRASS CAP STAMPED, "CITY OF AURORA G-0368" IN THE SOUTHWESTERLY WING WALL OF A CONCRETE INLET STRUCTURE LOCATED APPROXIMATELY 134 FEET SOUTH OF THE CENTERLINE OF EAST COLFAX AVENUE AND APPROXIMATELY 930 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE003
SITE BM: CITY OF AURORA BENCHMARK 037 ELEV=5405.22
A CHISELED SQUARE AT THE SOUTHEAST CORNER OF A CONCRETE INLET STRUCTURE APPROXIMATELY 90 FEET SOUTH OF THE CENTERLINE OF COLFAX AVENUE AND APPROXIMATELY 1420 FEET EAST OF THE CENTERLINE OF SABLE BOULEVARD. COA ID: 456606NE004

CAUTION - NOTICE TO CONTRACTOR

- ALL UTILITY LOCATIONS SHOWN ARE BASED ON MAPS PROVIDED BY THE APPROPRIATE UTILITY COMPANY AND FIELD SURFACE EVIDENCE AT THE TIME OF SURVEY AND IS TO BE CONSIDERED AN APPROXIMATE LOCATION ONLY. IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE FIELD LOCATION OF ALL UTILITIES, PUBLIC OR PRIVATE, WHETHER SHOWN ON THE PLANS OR NOT, PRIOR TO CONSTRUCTION. REPORT ANY DISCREPANCIES TO THE ENGINEER PRIOR TO CONSTRUCTION.
- WHERE A PROPOSED UTILITY CROSSES AN EXISTING UTILITY, IT IS THE CONTRACTOR'S RESPONSIBILITY TO FIELD VERIFY THE HORIZONTAL AND VERTICAL LOCATION OF SUCH EXISTING UTILITY, EITHER THROUGH POT-HOLING OR ALTERNATIVE METHOD. REPORT INFORMATION TO THE ENGINEER PRIOR TO CONSTRUCTION.



CITADEL ON COLFAX SUBDIVISION FILING NO. 1
LOT 2, BLOCK 8 - DRIVE LANE A (PRIVATE)
INFRASTRUCTURE SITE PLAN

EAST COLFAX AVE. / ALTURA BLVD.
AURORA, CO

#	Date	Issue / Description	Init.
1			
2			
3			
4			
5			
6			
7			
8			
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			

Project No:	NCP001
Drawn By:	JRC
Checked By:	SMB
Date:	2/5/2021

UTILITY PLAN

* TREE EQUIVALENTS (10 SHRUBS = 1 TREE AND 3 PERENNIALS = 1 SHRUB)

Refer to the aforementioned section. Update the table accordingly to match the actual standards.

Updated as requested.

Updated as requested.

LOT 2, BLOCK 8
CITADEL ON COLFAX
SUBDIVISION FILING NO. 1

GRANBY DITCH
TRACT H
CITIDALE ON COLFAX SUB FILING NO.1

EXISTING DETENTION POND A
TRACT E
CITADEL ON COLFAX SUBDIVISION
FILING NO. 1

CAUTION
UTILITIES EXIST WITHIN
CONSTRUCTION LIMITS. CONTRACTOR
IS RESPONSIBLE FOR IDENTIFYING
THEIR LOCATION PRIOR TO
CONSTRUCTION.

1. SCARY SIDES OF PLANTING PIT TO SETTING TREE.
2. REMOVE EXCESS SOIL APPLIED ON TOP OF THE ROOTBALL THAT COVERS THE ROOT FLAT. THE PLANTING HOLE DEPTH SHALL BE EQUAL TO THE ROOTBALL RESTS ON UNDISTURBED SOIL, AND THE ROOT FLAT 1/3" 5" ABOVE FINISH GRADE.
3. CUT OFF BOTTOM 1/3 OF SMIR-BEFORE PLACING TREE IN HOLE. CUT OFF AND REMOVE REMAINDER OF BACPLING TREE IS SET IN HOLE. REMOVE ALL NYLON TIES, TWINE, ROPE, AND OTHER PACKING MATERIAL. REMOVE ALL BURLAP FROM AROUND ROOTBALL.
4. TREE ROOTBALL IS NOT TO BE USED ON ANY NEW PLANTINGS.
5. EXCEPT IN LATE PLANTING SITUATIONS, AND ONLY THEN AFTER PLANTATION NUMBER, REMOVE ALL TWINE, TWINE, THEN WRAPPING TREE. WRAP FROM TRUNK FLAT TO LOWEST MAJOR BRANCH.
6. REMOVE ALL NURSERY STAGES AFTER PLANTING.
7. DO NOT OVER 3" CROWN USE, USE THREE STAKES OR DEADEN (AS APPROPRIATE), SPACED EVENLY AROUND TREE.
8. DO NOT ALLOW AIR POCKETS TO FORM WHEN BACKFILLING.

STAKING EXAMPLES (PLAN VIEW)

PREVAILING WINDS

PREVAILING WINDS

1 5 6