

Thomas Bassler, PE

8989 W 14TH Ave #307 Lakewood, CO 80215

ph: 303-842-8063

ELECTRICAL DESIGN REVIEW NOTICE

DATE: March 31, 2024

PROJECT: Taramahura Trucking

The original comments with our responses are listed below.

City Comments:

The electrical drawings for the subject project have been reviewed and the following correction items require a response:

7A. **Repeat Comment:** Add light pole detail, include pole height (maximum is 25 ft).

RESPONSE: Pole details have been added. SEE SHEET 13.

Sent via email

Thomas L. Bassler

Thomas L. Bassler, P.E.