

May 29, 2025

James Schireman, Mark Apodaca
Planner I
Planning Division
15151 E Alameda Parkway, Ste-2300
Aurora, CO 80012

**RE: Initial Submission Review – Jag Logistics Center at DIA – Site Plan Amendment
Case Number – 2018-6044-06**

Below are responses to permit review comments received **March 5, 2025** for the above-referenced project. The original comments are included for reference along with accompanying responses. Please contact our office if any additional information is needed.

Electrical Planning Department Review Comments

1. Where possible, relocate the delta symbols so they don't overlap with the site plan's content. Lines can be drawn to connect a delta to the bubbled area.
Response: All revision delta symbols have been relocated as needed.
2. Change the text in the text boxes to notes under the added key notes section or as new sheet notes. The text boxes currently obstruct the site plan content.
Response: Text boxes have been removed, and a note has been included to refer to electrical drawings for detailed information about installation.
3. The landscape screening requirement shouldn't be added to the site plan key notes as it might change in the future and we don't want confusion over which requirement is applicable. The ground equipment as proposed is meeting the intent of this section so no further screening is required.
Response: Note has been removed from all sheets.
4. Please include a revision bubble around the key notes bubble.
Response: Revision cloud has been added to all remaining electrical notes.

Electrical Fire/Life Safety Review Comments

1. Show the accessible EV parking space and aisle

Response: Electrical design has parking space and aisle shown as needed.

2. Provide grade slope percentages, 2% maximum slope in any direction in the accessible space and isle.

Response: Refer to sheet A1 for slope information.

3. Provide spot elevations at all corners of the EV accessible park space and isle.

Response: Refer to sheet A1 for spot elevations.

Respectfully,



Lauren La Bella, P.E, LEED AP BD+C

CMTA

lauren.labella@cmta.com | 720.915.9017

