



Right of Way & Permits

1123 West 3rd Avenue
Denver, Colorado 80223
Telephone: **303.571.3306**
Facsimile: 303.571.3284
donna.l.george@xcelenergy.com

March 21, 2025

City of Aurora Planning and Development Services
15151 E. Alameda Parkway, 2nd Floor
Aurora, CO 80012

Attn: Maria Alvarez

Re: Bennett Station Lateral - Site Plan Amendment #18, Case # DA-2201-12

Public Service Company of Colorado's (PSCo) Right of Way & Permits Referral Desk has reviewed the documentation for **Bennett Station Lateral - Site Plan Amendment #18**. Please be aware PSCo owns and operates existing overhead electric distribution facilities west of Cavanaugh Road. Bear in mind that per OSHA, a minimum 10-foot radial clearance must be maintained at all times from all overhead electric facilities including, but not limited to, *construction activities* and permanent structures.

As a safety precaution, PSCo would like to remind the developer to contact Colorado 811 for utility locates prior to construction.

Donna George
Right of Way and Permits
Public Service Company of Colorado dba Xcel Energy
Office: 303-571-3306 – Email: donna.l.george@xcelenergy.com